

Software Name: ioLogik R1241 Firmware

Version No.	Build Date No./ Release Date	Supported OS	Apply to Models	New Features/Enhancements	Bugs Fixed/Changes	Note
1.0	Build13031519	N/A	ioLogik R1241	New Features: 1. Newly release Enhancements: N/A	Bugs Fixed: N/A Changes: N/A	N/A
1.2	Build16012218	N/A	ioLogik R1241	New Features: N/A Enhancements: N/A	Bugs Fixed: 1. Fixed bit register unable to return data length issue 2. Fixed password not working issue 3. Fixed exception response without CRC 4. Fixed AO raw data from 0-65535 to 0-4095 - Note: Use ioSearch V1.12 to update ioLogik R1241 firmware form V1.0/V1.1 to V1.2. DO NOT use ioSearch V1.14 or later to configure ioLogik R1241 with V1.0/V1.1 firmware. - Note: Modbus master program needs to change AO raw data from 0-65535 to 0-4095 before ioLogik R1241 firmware is updated from V1.0/V1.1 to V1.2	N/A